

Approval Number 250555005
Test Report: PB2025001096



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

22nd May 2025

Fowry Tech.(Shandong) Co. Ltd.
North End of Gongye 2 Road,
Sangluoshu Industry Zone,
Huimin County
Binzhou City,
Shandong Province,
China

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS- FACTORY APPLIED PIPE & FITTINGS COATINGS.

5030

'EB-1003'. Factory applied, blue coloured epoxy powder coating. Apply and cure as per manufacturer's instructions 'Fowry Powder-001' dated '2020.3.20'. For use with water up to 85°C.

APPROVAL NUMBER: 250555005

APPROVAL HOLDER: FOWRY TECH.(SHANDONG) CO. LTD.

The Scheme reserves the right to review approval.

Approval 250555005 is valid between May 2025 and May 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager